

BID ADDENDUM NOTICE

07/27/2026

Bid Title:	Level 3 EVSE Distributed Power System		
Bid Number:	2600020 (EPIN 85726B0064)	Addendum #:	1
Bid Opening Date:	08/26/2026	Time:	10:00am EST
Procurement Analyst:	Christopher Likokas	Tel #:	(212) 386-0424 (CLikokas@dcas.nyc.gov)
Purchase Director:	Meline Hatchikian	Tel #:	(212) 386-0411

The following changes have been made to this bid:

Addendum No. 1

A “Transferring Data Between Rounds of an RFX” PDF Document has been added in Passport. Please refer to this document for information on how to transfer information from your previous RFX’s submissions, if applicable.

Please see Passport for the link to the virtual Bid Opening via Microsoft Teams.

QUESTIONS / CLARIFICATIONS / REVISIONS:

- **Revision of Contract Item# 1:**
 - From: SPLIT/DISTRIBUTED POWER UNIT 400KW MINIMUM
 - **To: SPLIT/DISTRIBUTED POWER UNIT 200KW MINIMUM**
 - Please see revised C-pages below.
- **CHAdEMO requirement:**
 - Is CHAdEMO capability mandatory for the base system? Typically, depot-type dispensers are not developed with CHAdEMO capabilities.
 - **Yes, CHAdEMO capability is required. This can be an adaptor, but the adapter must be part of the available cable configuration with the ability to charge at the spec level of the kW output of the dispenser.**
- **1,920 kW distributed system:**
 - Power Electronics also offers a 1,920 kW distributed charging system capable of serving up to 24 charging points simultaneously through dynamic power sharing. Would this be considered a compliant alternative if it meets or exceeds the required performance, or is the City specifically seeking individual systems closer to 200 kW? The centralized approach could significantly reduce both hardware and installation costs.
 - **If the unit meets or exceeds the technical requirements of the specification, it will be accepted.**

BID ADDENDUM NOTICE

- **RFID requirements:**

- Does each dispenser require an integrated RFID reader and local display? Alternatively, would vehicle identification via MAC ID within the platform be considered acceptable?
- **RFID reader is required on all dispensers. Not all NYC Fleet vehicles are equipped with MAC ID, OCPP identification solutions.**

Bids are due electronically in PASSPort by 08/26/2026 at 10:00am EST. DCAS strongly advises vendors to finalize and submit bids at least **48 hours prior to due date and time.** The City is not responsible for technical issues (e.g. internet connection, power outages, technology malfunction, computer errors, etc.) related to bid submissions.

All other terms and conditions remain the same.

DESCRIPTION

QUANTITY

UOI

UNIT PRICE

EXTENSION

THIS IS A CLASS AWARD.
YOU MUST BID ON ALL ITEMS IN THE CLASS TO BE
CONSIDERED FOR AN AWARD. IF YOU DESIRE TO BID
"NO CHARGE" ON AN ITEM IN THE CLASS YOU MUST SO
INDICATE.

CLASS/ZONE AWARD 1

ITEM NUMBER: 1.
SPLIT/DISTRIBUTED POWER UNIT 200KW MINIMUM
AS PER ATTACHED LEVEL 3 EVSE SPECIFICATION
DATED 04/15/2026

200. COMM. C075 06
EACH \$_____ \$_____

ITEM NUMBER: 2.
SPARE PARTS PACKAGE: REPLACEMENT PARTS,
AS PER ATTACHED LEVEL 3 EVSE SPECIFICATION
DATED 04/15/2026

20. COMM. C075 06
EACH \$_____ \$_____

TOTAL CLASS OR ZONE AWARD (ITEMS 1.00 THRU 2.00) 1\$_____

CASH DISCOUNTS

OFFERS OF CASH DISCOUNTS WILL NOT BE CONSIDERED
IN MAKING AN AWARD. PLEASE NOTE BELOW IF YOU
OFFER A CASH DISCOUNT AND, IF SO, THE DISCOUNT
TERMS.

DISCOUNT

YES NO TERMS % DAYS