Jamaica Station
Jamaica, NY 11435-4380
718-217-5477

Robert Free
President

MTA Long Island Rail Road

April 8, 2026

Alysondria Eason, P.E.
Hazen and Sawyer
498 Seventh Avenue, 11th Floor
New York, NY 10018

Subject: LON 26-037 Maurice A. Fitzgerald Playground On-Site Green Infrastructure
Project: 93-41 106th Street, Ozone Park, NY 11416

Dear Alysondria Eason:

The LIRR Engineering Structures group has reviewed your submission for the proposed Green Infrastructure Project at the above-referenced locations. Based on the submitted Modified Drawings C100, C101, C200-C202, C300-C302, & C500 dated March 2026 & Topographic Survey dated March 2026, we have determined that your work has minimal impact on the safe and timely operations of the LIRR, we take "**No Exception**". However, the Owner/Contractor shall adhere to the following:

- Fouling of LIRR track includes operation of equipment or any part of equipment, (i.e., crane booms) which could fall onto or within ten (10) feet of LIRR tracks. All parties are notified that fouling LIRR track without LIRR flag protection being present is a violation of Federal Law.
- Protection of LIRR property and facilities is the responsibility of Owner, and his designated Contractors. All damages to LIRR property caused by the project shall be repaired by the Owner/Contractor or repaired by the LIRR and charged to the Owner/Contractor.
- All damages to LIRR property caused by the project shall be repaired by the Owner/Contractor or repaired by LIRR and charged to the Owner/Contractor.

Should you have any questions, please contact Dominick Cervo, Project Engineer of my staff at 347-809-1005.

Sincerely,

Tom Shen

Tom Shen, P.E.
Managing Engineer - Civil Inspections

cc: P. Nebab, A. Cohn, D. Jimenez, E. Fontaine, F. Voltaire; File 2026043